CIVIL QUALITY CONSULTANTS & ENGINEERS

(Buildings Geo-Tech & Highway Materials Testing Laboratory)
An ISO 9001: 2015 Certified Company
NABL Accredited As Per ISO/IEC : 17025:2005 Laboratory

JAS-ANZ
ISO 9001:2000 CERTIFIED

Date:

To,
Executive Engineer
Dasarahalli Division
BBMP, Banglore.

Dear Sir

Subject: Project Management Consultancy for Construction Supervision Quality Control and Preparation of Bills for the Work of **"Providing Rain Water Harvesting Facilities in Ward NO 12 Shettyhalli** , Shettehalli Sub Division.
Regarding

Ref: 1. Work Order No:EE/DD/WO/414/19-20
2. Job Code : 012-20-000002

We are here with forwarding You M/S SHRUSTI SAMPADHA, Contractor, Banglore,Has been Satisfactory Completed above said work for a Gross value Rs.8,46,199/-(Rs Eight Lakhs Forty Six Thousand One Hundred Ninety Nine Only.)

Thanking you,

Yours faithfully,

CIVIL QUALITY CONSULTANTS & ENGINEERS Bangalore

Civil Quality Consultants and Engineers

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಯಂತರರು
ದಾಸರಹಳ್ಳಿ ಉಪವಿಭಾಗ, ದಾಸರಹಳ್ಳಿ ವಲಯ
ಬೃಹತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ
ಎಸ್.ಎಂ. ರಸ್ತೆ, ರವೀಂದ್ರನಗರ, ಬೆಂಗಳೂರು

Office & Laboratory : # 133, Bhuvaneshwarinagar, Dodda Basti Main Road, Bangalore - 560 056.
e-mail:civilqualityconsultants@gmail.com Ph: 080-23240644 / Mob: 8553518550

Scanned with CamScanner

CIVIL QUALITY CONSULTANTS & ENGINEERS

(Buildings Geo-Tech & Highway Materials Testing Laboratory)
An ISO 9001: 2015 Certified Company
NABL Accredited As Per ISO/IEC : 17025:2005 Laboratory

JAS-ANZ
ISO 9001:2000 CERTIFIED

Job No.: CQCE/BBMP/SS/W.No.12/2019-20 Date : 10.02.2020

TEST REPORT ON FINE AGGREGATES (SAND)
IS 383-1970 (RA- 2002)

Client : **Assistant Executive Engineer,** Shettyhalli Sub Division, BBMP, Bangalore.

Agency : **M/s. Shrusti Sampadha,** Contractor, Bangalore.

Name of Work : Providing rain water Harvesting Facilities in ward no.12 Shettyhalli, Shettyhalli Sub division, BBMP, Bangalore.

Date of Testing : 10.02.2020

Material : Sand Total wt. of aggregates in gms = **1000**

Is Sieve Size in mm	Weight Retained (gm)	Retained Weight in %	Cumulative Retained Weight in %	Cumulative Weight Passing in %	Spec.Limits For Zone-II
10	0	0	0	100	100
4.75	89	8.90	8.90	91.1	90-100
2.36	130	13.00	21.90	78.1	75-100
1.18	168	16.80	38.70	61.3	55-90
600 Micron	142	14.20	52.90	47.1	35-59
300 Micron	220	22.00	74.90	25.1	8-30
150 Micron	189	18.90	93.80	6.2	0-10

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಶೆಟ್ಟಿಹಳ್ಳಿ ಉಪವಿಭಾಗ, ದಾಸರಹಳ್ಳಿ ವಲಯ
ಪೂರ್ವತ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ
ಜೆಸ್.ಎಂ. ರಸ್ತೆ, ರವೀಂದ್ರನಗರ, ಬೆಂಗಳೂರು

For CIVIL QUALITY CONSULTANTS & ENGINEERS

Authorised Signatory

Office & Laboratory : # 133, Bhuvaneshwarinagar, Dodda Basti Main Road, Bangalore - 560 056.
e-mail: civilqualityconsultants@gmail.com Ph: 080-23240644 / Mob: 8553518550

Scanned with CamScanner